

Manufacture's Declaration

Confirmation of Operation in Member States and Application for certification


we hereby confirm that Solplanet inverters:

ASW1000-3000S-S
ASW3000-5000-S
ASW3000-10000-T
ASW8-20K-LT-G2
ASW3-20K-LT-G2 Pro
ASW25-40K-LT-G3
ASW30-50K-LT-G2
ASW40-50K-LT-G2 Pro
ASW3000-6000H-S2
ASW08-12KH-T1

can be set with the following grid protection parameters:

Parameter	Trip settings	Clearance time
Over voltage	230V+10%	0.5s
Under voltage	230V-10%	0.5s
Over frequency	50Hz+1%	0.5s
Under frequency	50Hz-4%	0.5s
ROCOF	0.4Hz/s	0.5s
Vector Shift	6 degrees	0.5s

Amsterdam, Netherlands 2022-9-7
AISWEI Technology (Shanghai) Co., Ltd.



Chen Yu (陈宇), Solution Manager